

MINUTES OF THE PRE-BID MEETING HELD ON 01.04.2024 AT THE OFFICE OF DEPUTY GENERAL MANAGER (E & SS), OIL INSTALLATION, KOLONNAWA AT 02. 00 P.M

**"REPAIRS TO TANK NO. 34 AT KOLONNAWA INSTALLATION"
KPR/22/2024**

Participants - CPSTL

- i. Mr. G.M.A. Bandara - Deputy General Manager (E & SS)
- ii. Mr. L.L.D.W. Jayathilaka - Actg. Engineering Manager (Premises & Civil)
- iii. Mr. D.H.P. Chathuranga - Deputy Engineering Manager (Inspection)
- iv. Mr. C.M. Samarakoon - Mechanical Engineer

The following company was collected the bidding document and participated for the pre bid meeting.

Company Name

- 01. M/s. Indo East Engineering & Construction (Lanka) Private Ltd,

At the beginning of the meeting, TEC Chairman – Mr. G.M.A. Bandara introduced the participants and asked to have a site visit after the pre bid meeting.

Then Mr. G.M.A. Bandara introduced the project to the participants and requested to forward queries / clarifications etc.

Queries raised at the pre bid meeting and answers of the CPSTL are tabulated as follows.

Queries raised at the pre bid meeting and the answers of the CPSTL

No.	Queries/Clarifications	CPSTL Answer
01.	As per Clause 6.5.7.3, the Contractor shall review the proposed design of the new RCC tank foundation and recommended soil improvement. Bidders need data on which above design has been done and any soil investigation information.	CPSTL can provide soil investigation report including recommendation done for new Tank No. D which is located 200 m away from Tank. No. 34 (Refer Annexure 1).
02.	Bidders need shell thickness, roof thickness	1 st Shell course – 19mm 2 nd Shell course – 15.1mm 3 rd Shell course – 14.1mm 4 th Shell course – 12.6mm 5 th Shell course – 10.8mm 6 th Shell course – 9.3mm 7 th Shell course – 6.0mm 8 th Shell course – 6.0mm Roof thickness – 5mm

Annexure 1 - Soil Investigation Report of the New Tank No. D

Abbreviations

ITB - Instructions to Bidders of ICTAD/SBD/02
COC - Conditions of Contract of ICTAD/SBD/02

Note: -

There were no quarries made after the site visit.

Bidders shall refer "Standard Bidding Document - Procurement of Works - Major Contracts; ICTAD publication no. ICTAD/SBD/02, Second Edition, January 2007", published by the Construction Industry development Authority (CIDA), Savsiripaya, 123, Wijerama Mawatha, Colombo 07 for ITB and COC.