



NOTE:

1. ALL DIMENSIONS ARE IN MILLIMETRES.
2. PIPES STANDARD ACCORDING TO API-5L
3. ALL PIPE BENDS TO BE SEAMLESS BEVELED END
4. STANDARD PIPE FITTINGS TO BE ACCORDING TO ASME 16.9
5. PIPE BENDS TO BE ACCORDING TO ASME 16.49

1	02/03/25	Tangent length Changed to 500mm	---	---	
REV.No.	DATE	DESCRIPTION	DRAWN	CHECKED	APPROVED

REVISIONS



CEYLON PETROLEUM STORAGE TERMINALS LIMITED
OIL INSTALLATION - KOLONNAWA
ENGINEERING FUNCTION

DESIGNED	G.H.J.CHAMINDA	PROJECT	MECHANICAL STANDARD DRAWING		
DRAWN	L D N K				
CHECKED	G.H.J.CHAMINDA				
DATE	01st October 2024	TITLE	DETAILS OF 18" R=3D PIPE BENDS		
APPROVED	ENGINEERING MANAGER	PROJECT NO	DWG NO.	REVISION	
		----	ST/PI/012	1	
		PAPER	SCALE	SHEET	
		A3	NTS	01 OF 01	

ALL RIGHTS PERTAINING TO THE REPRODUCTION, TRANSFORMATION AND USE OF THIS DOCUMENT IN ANY FORM OR MANNER
REMAIN THE EXCLUSIVE PROPERTY OF CEYLON PETROLEUM STORAGE TERMINALS LIMITED - KOLONNAWA